



SPEC. GROUP: 2025 RODEO

12KV RISER POLE ARRESTER REPLACEMENT
JOURNEYMAN EVENT

REV. DATE: REV. NO:

11/05/24 2

DRAWING NO.

C. MALONE

LETTER	QTY	STOCK NO	ITEM
A	1	10162	INSULATOR, PIN TYPE, 12KV POLYMER, HENDRIX HPI-55-4
	1	20498	INSULATOR PIN, POLE TOP
	2	10061	BOLT, CROSSARM, 5/8 IN X 16 IN (OR FIT TO MEASURE)
	2	10222	WASHER, SPRING, 5/8 IN TOP TIE, NO.2 AAC, PREFORMED UTF-1204
B	1	10504	CLAMP, HOT LINE, STIRRUP, 1/0-500, 1/0-397
	1	10094	CONNECTOR, HOT LINE TAP, 1/0
C	1	XXXXX	15° CUTOUT BRACKET 2-POSITION, 15 IN, CHANCE 15NM15AMSB
	1	22451	ARRESTOR, ABB 10KV SURGE ARRESTOR, HUBBEL 2216137324
	1	10120	CUTOUT, FUSED 100 AMP, 7.8/15KV, LBU II (CUTOUT), CHANCE C710-112PB
D		10083	CABLE, COPPER, 1/0, THHN, JACKETED
E			COPPER #2 STRAND
F			COPPER, #4 SOL.
G			COPPER, #4 CRIMP



SPEC. GROUP: 2025 RODEO

12KV RISER POLE ARRESTER REPLACEMENT
JOURNEYMAN EVENT

REV. DATE: REV. NO:

11/05/24 2

DRAWING NO.

C. MALONE